

VOC Content Test Certificate

Tuesday, 14th November 2017

Supplier: Würth Australia Pty Ltd (U2, 1 Healey Rd, Dandenong South, VIC, 3175).

Sample Description: Würth Bond + Seal (Black colour)

Date Tested: November 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B</p>	<p align="center">Würth Bond + Seal</p>
<p>General purpose adhesives and sealants: 50 grams per Litre as VOC content per material</p> <p>Acoustic sealants, architectural sealant, waterproofing membranes and sealant: 250 grams per Litre as VOC content per material</p>	<p align="center">47 gram per Litre as VOC content per material</p>
<p><i>We hereby certify Würth Bond + Seal (including 310 mL cartridges, 600ml sausage/bag, and 70ml tube in white, grey, sand and black colour) is below the VOC Content limits of the above stated categories specified by Green Building Council of Australia's Green Star Design & As Built and Green Star Interiors</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV171114